







# Optimization Programs for Enhanced Drinking Water Quality West Fargo, ND

April 22, 2025



#### Agenda



- Overview of two established national drinking water optimization programs
  - Area-Wide Optimization Program (AWOP)
  - Partnership for Safe Water (PSW)
- Minnesota DOH experiences: Comprehensive Performance Evaluations
- Workshop introduction: Turbidity data interpretation and data integrity
- Tabletop exercise: Turbidity data evaluation and interpretation



#### **1993 Milwaukee Outbreak**

Diarrhea Onset & Max Plant Effluent Turbidity









The Area-Wide Optimization Program, referred to as AWOP, was developed utilizing the foundation of the EPA Composite Correction Program (CCP), an optimization program that was developed for drinking water treatment plants in the 1980s through a pilot project with the State of Montana drinking water program and Process Applications, Inc.

AWOP



### AWOP Map





5



#### Ultimate Goal of AWOP







#### **Partnership for Safe Water**







#### **Composition Correction Program**



Drinking Water Treatment optimization was developed and documented in 1990.

\$€PA





#### **Composite Correction Program**



### • CCP

- Comprehensive Performance Evaluation (CPE)
  - Assess Performance
  - Identify Performance Limiting Factors (PLFs) Related to Administration, Design, Maintenance and Operations
- Comprehensive Technical Assistance (CTA)
  - Address PLFs
  - Continue Measuring Performance







#### **PSW Self-Assessment Guides**





Converting facilitated optimization tools to a Self-Assessment Approach



### **AWOP Development**



- CPE training (CO, KY, MA, MD, MT, PA, RI, TX, WV)
  - States generally comfortable with performance evaluation portion, recognizing that the resource commitment > typical plant inspection
  - Many trained state CPE teams disbanded over time
    - Inspections required of all water systems, optimization efforts were not
    - No organizational structure to maintain CPE capability
  - States less comfortable with technical assistance portion of program
    - Resource commitment perceived as too great
    - Technical assistance role not embraced by all states
- Multistate approach (1997)



### **AWOP Development**



## Lessons Learned:

we needed a strategy, <u>not</u> just a toolbox

#### Stage 1: EMERGENCY

- Meet immediate needs with compassion
- Create clear, accurate information

#### Stage 2: TRUST

- Slow down and listen
- Build relationships throughout the community

#### Stage 3: COLLABORATE

- Create collaborative formats to identify and meet longer term needs
- Keep showing up, keep listening, trust the community

#### Stage 4: MAINTAIN

- Support community efforts to move forward
- Keep showing up, keep listening



### **AWOP Model**







### **Optimization Goals**



- Developed and Endorsed by the NOLT
- Monitoring Goals
  - Sampling Locations
  - Sampling Frequency
  - Modified to keep up with technology improvements in monitoring instrumentation
- Performance Goals
  - Enhance public health protection
  - Implementable

Area-Wide Optimization Program Disinfection By-Product and Distribution System Optimization Goals and Guidelines

#### Monitoring & Operating Goals Summary

Category	Goal/Guideline	Status	Description	References
Disinfection By-Product	Plant Effluent Monitoring Goal	Adopted	<ul> <li>Collect quarterly total trihalomethane (TTHM) and haloacetic acid (HAA5) samples at the plant effluent with distribution system compliance sites.</li> </ul>	
Disinfection By-Product	Enhanced Coagulation Monitoring Goal <sup>1</sup>	Adopted	<ul> <li>Collect monthly raw and treated water total organic carbon (TOC) samples (only applies to parent systems).</li> </ul>	
Disinfection By-Product	Disinfection Monitoring Goal	Adopted	<ul> <li>Record disinfectant residual, temperature, and pH at maximum daily flow in the treatment plant for CT calculations.</li> </ul>	
Distribution System	Disinfection By- Product Monitoring Goal	Adopted	<ul> <li>Collect quarterly DBP samples at all compliance locations at systems in compliance with the Stage 2 0/DBP Rule.</li> <li>Collect monthly DBP samples at all compliance locations at system not in compliance with the Stage 2 0/DBP Rule.</li> </ul>	
)istribution System	Disinfectant Residual Monitoring Goal	Adopted	<ul> <li>Monitor disinfectant residual at bacteriological and DBP compliance sites, all active distribution system entry points, all storage tanks (preferably while draining), and at a minimum of four critical sites (one in each quadrant of the system) identified by investigative sampling.</li> <li>Conduct monitoring at least monthly and more frequently during warmer weather.</li> </ul>	
istribution System	Chloramination Process Monitoring Goal	Adopted	<ul> <li>Monitor free ammonia in raw water, prior to the addition of chlorine in the treatment plant, and in the plant effluent on a routine basis. Raw water should be monitored at least weekly and other locations should be monitored at least daily. The frequency of analysis at ach location chould be adjusted based on variability.</li> </ul>	American Water Works Association, 2013

Area-Wide Optimization Program Disinfection By-Product and Distribution System Optimization Goals and Guidelines

#### Performance Goals & Guidelines Summary

Category	Goal/Guideline	Status	Description	References
Disinfection By-Product	Plant Effluent Performance Goal	Adopted	<ul> <li>Adopt System Specific Targets: Discrete value or range based on a running annual average (RAA). Recommended goal should be 30% to 50% of long-term locational running annual average (LRAA) goals (e.g., 20-30 ppb for TTHM, 15-20 ppb for HAA5).</li> </ul>	
Disinfection By-Product	Enhanced Coagulation Performance Goal <sup>1</sup>	Adopted	<ul> <li>Meet Stage 1 D/DBP Rule TOC removal requirements for enhanced coagulation, which are based on source water alkalinity and TOC levels, or an alternative compliance criteria, as ARA of the performance ratio (PR) (actual/required removal) plus a factor of safety of 10% (or PR ≥ 1.1).</li> </ul>	
Disinfection By-Product	Disinfection Performance Goal	Adopted	Meet CT requirements to achieve inactivation of Giardia and viruses plus a system- specific factor of safety.	
Disinfection By-Product	Disinfection By- Products Performance Goals	Adopted	<ul> <li>Individual Site Goal: Quarterly maximum LRAA TTHM/HAA5 values not to exceed 70/50 ppb.</li> <li>Long-Term System Goal: Average of maximum LRAA TTHM/HAA5 values not to exceed 60/40 ppb (the average of the last 8 quarters cannot exceed 60/40 ppb).</li> </ul>	
Distribution System	Disinfection Performance Goals	Adopted	<ul> <li>Maintain 2 0.20 mg/L free chlorine residual at all monitoring sites in the distribution system, at all times in systems that use free chlorine as a secondary disinfectant.</li> <li>Maintain 2 1.50 mg/L monochloramine residual at all monitoring sites in the distribution system, <u>at all times</u>. In systems that use chloramines as a secondary disinfectant.</li> </ul>	American Water Works Association, 2013 American Water Works Association, 2017
Distribution System	Storage Tank Operational Guideline	Adopted	<ul> <li>Maintain an average turnover time &lt; 5 days; or establish and maintain an acceptable water turnover rate at each storage facility to maintain water quality;</li> <li>Maintain good mixing (i.e., PR<sup>2</sup> ± 1) at altimes; for tanks where the PR cannot be calculated, adequate mixing (i.e., uniform water quality; should be confirmed by alternate means (e.g., tank profiling/water quality; singling).</li> </ul>	

National <sup>1</sup>Apples to surface water and groundwater under the direct influence of surface water involvent plants. <sup>1</sup>Minks and surfaces water in the industry into the FDN Stores Task Assessment Screenblant can Water Work ociation, 2013



### Status Component



TABLE 2. 2022 MICROBIAL STATUS, H	Prio	RITIZEE	o Facil	ITIES.																	
System Name				2022 Score	#>1. NTU	0 i	#>0.30 NTU	#>0.1(	0 NTU												
SOUTHERN WATER & SEWER DISTRICT				2090		0	0		2090							Data bacad Accoccment a	nd				
CARLISLE WATER DEPARTMENT 1341 0 1 1338							Data-Daseu Assessment and														
MOUNTAIN WATER DIST				1228		0	0		1228		Drioritization										
ALBANY WATER WORKS				1145		0	0		1145							PHOMUZation					
WOODSON BEND PROPERTY OWNERS ASSO	C			1050		0	0		1050												
EDMONSON CO WATER DISTRICT				972		0	0		972												
CAMPBELLSVILLE MUNICIPAL WATER				938		0	0		938												
CAWOOD WATER DISTRICT				904		0	0		904												
PIKEVILLE WATER DEPARTMENT				616		0	0		616												
PINE MT SETTLEMENT SCHOOL				567		0	0		567												
TOMPKINSVILLE WATER WORKS				562		0	1		559												
BARDSTOWN MUNICIPAL WATER DEPT				502		0	5		487												
HAZARD WATER DEPARTMENT	_			463		0	0		463												
SPRINGFIELD WATER WORKS														Con	nmu	inity Surface Water Systems with Conventiona	al Treatmen	it			
MT VERNON WATER WORKS													202	20 W	lest	Virginia Microbial "Public Health Risk" catego	orv ranking.				
EDMONSON CO WATER DISTRICT	11	1 13	8	13	19	19	18	12	8	12	7	15	8	3	6	←number of zero points WTPs per year	, ,	Risk T	o Public	Health	
LANCASTER WATER WORKS													-								
MARION WATER DEPARTMENT	18	3 17	16	15	14	13	12	11	10	09	08	07	06	05	*04			DIST	Overall		95%tile
ASHLAND WATER WORKS	Rł	K RK	RK	RK	RK	RK	RK	RK	RK	RK	RK	RK	RK	RK	RK	System Name	PWSID #	R	Score	Risk	CFE
SALYERSVILLE MUNICIPAL WATER		1 14	1 9	) 1	1	1	1	1	1	1	3	1.2	1 tie	13	121	Putnam PSD (12 tzp), 3 fltr (1.6 MGD 24/7) DW36Ex129	WV3304011	2	0	L	0.07
ALBANY WATER WORKS	1	2 1	1	14	1	20	) 1	1	9	17	13	29	55	29	100	WVAWC-BLUEFIELD DISTRICT, 4 fltr (1.3 MGD 24/7)	WV3302835	1	0	L	0.04
NORTHERN KENTUCKY WATER DISTRICT	4	4 1	1	1	1	1	1	1	1	13	10	7	4	5	113	WVAWC-BLUESTONE PLANT, 4 fltr (2.2 MGD 24/7)	WV3304513	1	0	L	0.02
KUTTAWA WATER DEPARTMENT	4	4 1	1	1	1	1	1	1	1	1	2	9	11	23	118	WVAWC-NEW R REG WTP (11 tzp) 3 fltr (2.2 MGD 24/	WV3301046	1	0	L	0.04
DAWSON SPRINGS WATER & SEWER		1 1	40	) 1	1	1	1	1	1	1	1	1.3	5 tie	2	123	WVAWC-WESTON (15 tzp) 4 fltr(1 MGD 24/7)	WV3302104	6	0	L	0.06
CORBIN UTILITIES COMMISSION		1 14	1 9	9 14	20	20	) 55	12	32	34	11	14	28	36	115	Morgantown (Evo 0.04-µm uF) Hyb 8 flt (9.5 MGD 24/7)	WV3303111	6	0	L	0.02
FRANKFORT PLANT BOARD		1 14	19	) 1	1	1	1	1	1	1	6	11	9	53	91	HURRICANE TOWN OF (9 tzp) 2 fltr	WV3304005	2	0	L	0.07
MOREHEAD UTILITY PLANT BOARD		1 14	19	67	60	1	1	1	1	1	5	15	17	48	82	WVAWC-Hunt'n(7 tms 0 pts)12 fltr(9.3 MGD 24/7)	WV3300608	2	0	L	0.07
RUSSELL WATER COMPANY				123		U	12		87												
WINCHESTER MUNICIPAL UTILITIES				118		0	0		118												
GREENVILLE UTILITIES COMMISSION				112		0	0		112												



PROCESS APPLICATIONS,

INC.



#### WA State Rapid Rate Plant Performance Trends





### **Targeted Performance Improvement**



Performance Limiting Factors Summary

- A Major Effect on a long-term repetitive basis
- B Moderate effect on a routine basis or a major effect on a periodic basis
- C Minor effect

# Example Performance Limiting Factors

- **A** Design (Sedimentation)
- A Operations (Representative Sampling)
- A Design (Process Controllability)
- A Administration (Reliability)
- **B** Administration (Policies)
- **B** Design (Filtration)
- C Design (Pre-sedimentation Basin)



# Targeted Performance Improvement





Addressing Performance Limitations



**Mn Demand Testing** 



New State CPE Demonstration



#### Maintenance







- <u>Enhance</u> the AWOP continuously using data-based evaluation and adjustments.
- <u>Integrate</u> AWOP principles into all aspects of the drinking water program.
- <u>Sustain</u> AWOP within the organization.



### **AWOP Strategy**



- Primacy Agency Implementation
  - State Public Water System Supervision Program personnel adopt, promote and implement the optimization of drinking water treatment and distribution processes.
- National Program Implementation
  - Managed by EPA-OGWDW.
  - National Optimization Leadership Team (NOLT) advises OGWDW
    - Comprised of ASDWA & EPA Regions.
  - Participation is voluntary.





### **PSW & AWOP Information**



- PSW: <a href="https://www.awwa.org/programs/partnership-for-safe-water/">https://www.awwa.org/programs/partnership-for-safe-water/</a>
- EPA: <u>https://www.epa.gov/sdwa/drinking-water-optimization-program</u>
- ASDWA: <a href="https://www.asdwa.org/awop/">https://www.asdwa.org/awop/</a>
- Content to be found on these websites
  - AWOP Overview
  - Goals & Guidelines
  - AWOP Tool descriptions, including recordings
  - Water Quality Impacts
  - Interactive map of State Agency AWOP webpages



#### Agenda



- Overview of two established national drinking water optimization programs
  - Area-Wide Optimization Program (AWOP)
  - Partnership for Safe Water (PSW)
- Minnesota DOH experiences: Comprehensive Performance Evaluations
- Workshop introduction: Turbidity data interpretation and data integrity
- Tabletop exercise: Turbidity data evaluation and interpretation

# Turbidity Data Interpretation and Integrity

West Fargo, North Dakota April 22, 2025

# Background for Turbidity Optimization Performance Goals

- Public Health Protection Challenge
  - Waterborne disease outbreaks are commonly linked with protozoan parasites:
    - Giardia and Cryptosporidium are routinely detected in North American water supplies
    - 0.2 log or less inactivation of *Cryptosporidium* with free chlorine at 5 15 mg/L for 60 240 minutes (*Finch, 1995*)
  - Meeting existing compliance levels not always effective in preventing disease.

# **Optimized Performance Reduces Risk**

- Optimization requires treatment <u>beyond regulatory levels</u>.
- Focus on multiple barrier strategy to enhance plant performance:
  - Particle removal (i.e., turbidity).
    - Coagulation/flocculation + sedimentation + filtration
  - Disinfection



**Disinfection Barrier** 

### **Basis For Sedimentation Basin Goals**

- Dugan (2001) Pilot scale work to assess Cryptosporidium removal through conventional sedimentation (USEPA):
  - Sedimentation removal under sub-optimal coagulation averaged 0.2 log Crypto.
  - Sedimentation removal under optimal coagulation averaged 1.3 log *Crypto*.
  - Removals positively correlated with turbidity removal.

# **Basis For Filtered Water Turbidity Goals**

- Emelko (2000) Pilot scale work to assess Cryptosporidium removal through filtration (University of Waterloo):
  - Stable operation: 5 to 6 log (turbidity ~ 0.04 NTU)
  - End-of-run: 2 to 3 log (turbidity increase to 0.10 NTU)
  - Breakthrough: 1.5 to 2 log (turbidity increase to 0.3 NTU)

# Removal of Organisms Based on Treatment Type and Conditions



(Ref. Amburgey 2007 WQTC.)

# **Sedimentation Performance Goals**



- Max Daily Turbidity:
   < 2 NTU 95% time when source turbidity >10 NTU
- Max Daily Turbidity:
   ≤ 1 NTU 95% time when source turbidity ≤ 10 NTU
- Frequency of sampling:
  - Grab every 4 hours
  - Continuous capture highest value per day from SCADA

# Filtration Performance Goals for Conventional Rapid Rate Filters

- Max Daily Turbidity Individual Filter and Combined Filter Effluent: < 0.10 NTU 95% of the time</p>
- Maximum Turbidity: < 0.30 NTU</p>
- Continuous monitoring for IFE and CFE (capture highest value per day from SCADA)



# Optimization Approach – Draw the Graph!



# A Tool to Manage Performance Data

- Optimization Assessment Spreadsheet
  - Allows for viewing trends over 3 years
    - Most analyses are done using a specified 12-month period of time.
  - Software for direct filtration, conventional, and membrane plants
  - Provides graphs, charts and tables allowing strategic insights into plant performance.

#### **XYZ Water Treatment Plant**

#### **Treatment Barrier Performance Summary**





						$\sim$		
ANNUAL DATA	Avg	Min	Max	RSQ	9	5%	Opt. Goal	Reg.
	NTU	NTU	NTU		/ N	τυ	% Values	% Values
Raw Turbidity	23.0	1.8	191.4	n/a	1	73.1	n/a	n/a
Max. Settled Turbidity	1.6	0.4	4.5	0.00		3.2	76	n/a
Max. Filtered Turbidity	0.25	0.05	5.00	0.00		0.52	15	n/a
Combined Filtered Turbidity	0.09	0.03	5.00	0.00		0.15	88	100

RSQ = Correlation Coefficient for two selected data sets (> ~ 0.25 suggests correlation)

95% = 95th Percentile value for data set

Opt. Goal = % of values in data set that are less than or equal to the selected optimization turbidity goal

Reg. = % of values in data set that are less than or equal to the regulated turbidity requirement



#### **Sedimentation Performance Summary**



Filtration Performance Summary (Filters 1 - 4)


	Settled Water Turbidity							Filtered Water Turbidity																	
	95th Percentile Values (NTU) % Values Meeting Goal				95th Percentile Values (NTU)												% Values Meeting Goal All Filters								
	Sed 1	Sed 2	Sed 3	Sed 4	All Sed	3 NTU	2 NTU	1 NTU	Filter 1	Filter 2	Filter 3	Filter 4	Filter 5	Filter 6	Filter 7	Filter 8	Filter 9	Filter 10	Filter 11	Filter 12	Combined	All Filters	0.3	0.2	0.1
Aug-15	2.95	2.95	3.10		0.04	04.00		14.0	0.27	0.32	0.26	0,64	0.00	0.04	0.40	0.3	4				0.24	0.30	95.16	63.31	19.4
Sep-15	2.89	2.28	2.18	Wo	orst S	ed Bas	sin	32.2	0.18	0.22	0.13	0	W	orst F	ilter	0.2	1				0.14	0.19	100.00	96.67	69.6
Oct-15	2.37	2.20	1.50		For N	lonth		46.6	0.14	0.16	0.13	0.	F	or Mo	nth	0.1	5				0.07	0.15	99.19	98.79	83.9
Nov-15	1.26	1.00	0.88			100.00	100.00	93.0	0.12	0.18	0.12	0.12	0.11	0.10	0.10	0.18	8				0.08	0.16	100.00	98.75	86.3
Dec-15	0.92	0.69	0.71	$\sim$	0.81	100.00	100.00	98.9	0.18	0.19	0.14	0.15	0.13	0.21	0.16	0.10	6				0.09	0.17	99.19	98.39	81.5
Jan-16	1.80	1.60	1.40		1.60	100.00	100.00	55.9	0.25	0.72	50.34	0.67	0.17	0.21	0.19	0.2	1				0.12	0.25	95.97	87.90	72.6
Feb-16	- YN 1.06	م 1.16	1.16		1.17	100.00	98.85	88.5	0.15	0.22	N 0.22	0.20	0.20	0.22	0.22	0.4	3				0.09	0.22	97.84	91.38	78.4
Mar-16	1.50	1.85	1.90		1.88	100.00	97.85	41.9	0.15	0.29	0.17	0.35	0.17	<u>_</u>	0.05						0.09	0.23	97.98	90.73	78.6
Apr-16	2.97	3.11	4.08		3.56	90.00	67.78	33.3	0.19	0.15	0.21	0.19	0.14	H	lighe	st Va	lue,				0.13	0.20	99.58	95.00	82.5
May-16	2.40	2.85	3.35		Hig	hest \	/alue	.4	0.10	0.10	0.09	0.09	0.10		All I	Filter	S				0.07	0.11	100.00	100.00	92.7
Jun-16	3.36	3.11	3.37		Ali	Sed B	asins	.7	0.21	0.10	0.10	0.12	0.10	0.12	0.10	0.1	3				0.09	0.13	98.33	96.67	88.8
Jul-16	2.50	2.20	<b>∧</b> 2.45	1	2.44	100.00	82.80	18.3	<b>1</b> 6	<b>N</b> .14	1 0.20	0.62	0.08	0.15	0.10	0.12	2				0.20	0.16	97.98	95.97	85.9
Yr. 95%	2.60	270	2.80	2	>				0.21	0.24	1 7.23	<b>-</b> 0.24	0.19	0.21	0.21	0.2	2				0.15				
Yr. Goal	86.5%	26.5%	84.3%		$\mathbf{k}$				281%	72.7%	<         77.8%	73.5%	80.6%	77.0%	80.6%	73.0%	6				88.3%				
			$\overline{\Lambda}$	$\sim$						μA	M														





# **Data Integrity**

A process to maintain and assure the accuracy and consistency of data over its entire life cycle.

#### **Based on Turbidity Data Life Cycle**



## **Settled Water Sample Considerations**

- Consider location, length of sample line, and sample flow rate to turbidimeter(s).
- Check sample line condition and turbidimeter cleaning frequency.
  - Solids deposition in line and meter often contributes to turbidity spikes.
- Check for delayed start of sampling (e.g., solenoid that opens sample line 15 minutes after start-up).



# Individual Filter Effluent Sampling

- Sample tap location issues:
  - Should be able to accurately measure turbidity during both filter-to-waste and filter-to-clear well periods.
  - The graphic shows a stagnant zone at the monitoring location during filter-to-waste.



## **Sample Tap Location for Turbidimeters**

Sample tap location: Best location is the side of the pipe or a quill that allows sample to be taken from the pipe center.



Source: Hach Company (2014)

1	Poor	4	Sediment (typical)
2	Poor	5	Good
3	Air (typical)	6	Best

Figure 1: Sample Line Location in Process Stream (Hach Company)

## Sample Line Integrity



**IFE Sample Tap Relocation Project** 



What the Operators Found!

# **CFE Sample Considerations**

- Location of CFE sample line.
  - Is CFE representative of all filters?
  - Post clear well locations can be problematic:
    - Floc due to pH changes and chemical addition
    - Turbulence from high service pumps
- Length of sample line to turbidimeter and flow rate.



## Sample Line pumps can add error

- Individual filter effluent turbidity samples pumped to remote turbidity location.
- Operators experienced frequent problems with air and turbulence causing turbidity spikes.
- Access to IFE sample tap and line is through confined space ~ 20 feet below access hatch (plant < 10 years old).</li>





## **Turbidimeter Considerations**

Bench top vs continuous instruments

- Using a benchtop introduces additional potential error, due to sample handling and sample cell integrity.
- Newer technologies are more accurate/reliable
  - Laser technology.
- Continuous readings from one manufacturer to another may be slightly different.

# Turbidimeter Verifications and Calibrations

#### Verifications

- Usually done at least weekly
- Compare measured result to known standard (primary or secondary) or to another instrument.
- If instrument reading is our of range, conduct a calibration
- Calibrations
  - Usually done at least quarterly
  - Adjusts the reading according to a primary standard.

## **Turbidity Verification Procedures**

Common perception that portable and bench turbidimeters are not accurate for comparing to online instruments when measuring low turbidity water (i.e., IFE, CFE).

House P	(mg/L)	ricesiquar	Gravity Filter CFE Turbidity (NTU)						
		Within			Within				
Analyzer	Grab	+/- 5%	Analyzer	Grab	+/- 5%				
1.28	1.31		0.08	0.10					
1,50	1.62		0.07	0.13					
1.38	1.50		0.07	0.11					
1.44	1.40		0.08	0.10					
1.41	1.58		0.07	0.15					
1.47	1.46		0.07	0.14					
1.42	1.50		0.08	0.13					
1.40	1.44		0.09	0.18					
1.42	1.46		0.11	0.31					
1:35	1.42		0.16	027					
1.59	1.70		0.10	0.29					
1.51	1.65		0.07	0.15					
1.49	161	<	0.08	0.43					
1.43	1.58		0.08	011/0.10					
1	1. 60								

Online Turbidimeter O&M and Configuration (settings) Assessment

# Online Turbidimeter O&M and Configuration (settings)

#### Turbidimeter O&M:

- Calibration practices
- Verification practices
- Photocell inspection and cleaning
- Bulb replacement frequency
- Flow rate check frequency
- Availability of maintenance logs
- Turbidimeter settings:
  - Signal averaging
  - Bubble reject
  - Error hold mode
  - Output span



# Online Turbidimeter O&M and Configuration (settings)

- Signal output range 0 to 1 NTU common finding for IFE but will result in *"capping"* of data during filter upsets.
  - Potential compliance issue with determining the daily max. value.
- Check controller response to loss of communication with sensor default is to report last known value.
  - Occurred in a large plant, and *"last known value"* was sent to SCADA for
     > 24 hours before operator aware of problem.



# Turbidimeter Signal Verification and Data Logging



## Data Transmission: Analog to PLC Scenario

Digital data display is showing the value coming from the sensor, before it has been converted to analog.

Sensor

At the controller the signal is converted from digital to analog. The PLC converts the analog signal back to a digital signal for communication with the SCADA system.

Digital



SCADA Data Storage



Controller (SC 200)



PLC

## **Turbidity Verification Procedures**



- Using proper techniques and calibrated meters results in acceptable verification.
  - Grab sample results should be within 0.05 NTU of online instrument.
  - Requires awareness of sample cell integrity, cell indexing, de-gassing sample, access to representative turbidimeter sample location.

# Interpreting and Reporting Turbidity Data

# Turbidity Data Tracking and Reporting

- Establish the current data recording protocol.
  - Include raw through CFE turbidity sample locations.
- Consider all data sources (e.g., operator logs, SCADA downloads).
  - Determine which data source is used for recorded turbidity values.
  - How are maximum daily IFE and CFE values determined?

# **Example IFE Max Day Verification**



## Summary

- Optimized performance of the settling and filtration barriers protect public health
  - Performance goals can be used to measure performance.
- OAS spreadsheet can be used to interpret performance data.
- Data integrity is an important aspect of interpreting performance.
  - Accurate data can bring about important operational decisions.



#### **CPE Overview in MN**

Indran Kamalanathan | SWTR Compliance Engineer

#### **CPEs in Minnesota**

- MN has completed three CPEs since 2022
  - Thief River Falls, Ely, and International Falls

- Provides the plant and state staff with a deep understanding of CPE focus areas
  - Design Plant unit process capabilities
  - Operations Plant staff and how the plant is run day to day
  - Admin Plant management and planning

### **Optimization Goals**

- Enhanced treatment targets with the goals of improved public health outcomes and compliance
- Multiple barriers operating effectively can produce the highest quality water
- Turbidity:
  - Daily Maximum Sedimentation Turbidity does not exceed 2 NTU (based on raw >10 NTU)
  - Daily Maximum Filter Turbidity does not exceed 0.1 NTU in IFE and CFE measurements
  - Filter Backwash Spike does not exceed 0.3 NTU and returns to 0.1 NTU within 15 minutes

#### **CPE** Process

- Pre-meeting and planning with PAI and systems
- On-site evaluation
  - Day 1 Kickoff and Plant Tour | Project Team Breakout
  - Day 2 Special Studies and Project Team Work
  - Day 3 Wrap-up Studies | Factor Deliberation
  - Day 4 Exit Meeting Presentation
- Report Generation
- Regular Check-In with District Engineer and SWTR Team



Figure 16. Filter No. 1 surface wash arm.



Figure 17. Filter expansion measurement tool.

### **CPE Activities and Plant Studies**

#### **Baseline Studies**

- Admin Interviews
- Operation Interviews
- Major Unit Process Analysis
- Historical Data Analysis

#### Special Studies

- Filter Bed Study
- Backwash Performance Study
- UV/TOC Removal Study
- Chemical Feed Verification
- Plant Meter Verification
- Turbidity Data Analysis
- Chloramination Study

### **Factor Determination**

- Plant Performance Limiting Factor List is generated and categorized based on effect
  - A Major long-term
  - B Moderate routine or Major Periodic
  - C Minor
- Provides the plant with a key prioritized list that leads them naturally to optimization

Rank	Rating	Performance-Limiting Factor (Category)
1	А	Administration/Plant Administrators/Policies
2	А	Administration/Plant Administrators/Supervision
3	А	Operation/Process Control/Water Treatment Understanding
4	А	Operation/Testing/Process Control Testing
5	А	Operation/Process Control/Application of Concepts and Testing to Process Control
6	А	Design/Unit Process Adequacy/Process Controllability
7	В	Administration/Plant Staff/Number
8	В	Operation/Process Control/Operational Guidelines/Procedures
9	В	Maintenance/Maintenance Program/Maintenance Resources/Materials and Equipment

#### **Example Factor Description**

#### Process Control Testing – Operations (A)

Strategic process control testing and representative sampling of each treatment process is necessary to make sound process control decisions related to the ability of each treatment barrier to prevent contamination.

- Operators currently do not test daily for raw turbidity, temperature, or pH. If a raw water quality change were to suddenly occur, response time may be delayed as a result.
- Operators are not testing settled water turbidity, free ammonia, or monochloramine in finished water. These analyses are necessary for optimizing the clarification and chloramination processes.

## **Common Findings So Far**

- Admin Policies: Plants need clear optimization goals to produce the best quality water
- Admin Plant Coverage/Staffing: Plants need staff with sufficient time to perform optimization work
- Design Process
   Controllability: Limited
   ability to modify processes
   to improve water quality
   (chemical feed location, filter
   backwashing settings)
  - Design Unit Process Adequacy – Disinfection: Disinfection taking place in plant does not sufficiently meet CT
- Operation Water Treatment Understanding/Application: Lack of surface water focused knowledge and minimal in plant studies to help guide operation
- Operation Process Control Testing: Insufficient data collection to fully understand plant operation

#### **Benefits for Water Plants**

- Helps building understanding at all levels of limitations and needs
- Provides water operators with deeper understanding of their process
- Builds rapport with state staff for questions and concerns
- Helps limit and address violations preemptively and direct plant improvements
- Leads to more confidence in plant operation

### Benefits for State Program

- Builds deeper technical knowledge of water treatment principles
- Engages staff in challenging work
- Builds knowledge of water treatment plant for compliance and technical assistance work
- Helps determine program wide needs
- Develops connections with broader AWOP community



# Thank You!

#### **Indran Kamalanathan**

Indran.kamalanathan@state.mn.us

#### Surface Water Treatment Optimization Training West Fargo, North Dakota April 22, 2025

#### **AWOP Workshop**

**Prepared by:** 

Process Applications, Inc. 2627 Redwing Road, Suite 340 Fort Collins, CO 80526

and

U.S. Environmental Protection Agency Office of Ground Water and Drinking Water Technical Support Branch 26 W. Martin Luther King Drive Cincinnati, Ohio 45268

#### AWOP Workshop

#### **Instructions**:

Collecting and assessing plant performance data is an important step to establish the status of a plant relative to achieving optimized performance goals. The purpose of this workshop is for the participants to explore methods for summarizing and evaluating a plant's historical performance data and to develop interpretation skills.

Below are the optimization performance goals for the sedimentation barrier and the filtration barrier.

Barrier	Performance Goals							
Sedimentation	<ul> <li>Max Daily Turbidity:         <ul> <li>2 NTU 95% time when source turbidity &gt;10 NTU</li> </ul> </li> <li>Max Daily Turbidity:         <ul> <li>1 NTU 95% time when source turbidity ≤ 10 NTU</li> </ul> </li> <li>Frequency of sampling:             <ul> <li>Grab – every 4 hours</li> <li>Continuous – capture highest value per day from SCADA</li> </ul> </li> </ul>							
Filtration	<ul> <li>Max Daily Turbidity: ≤ 0.10 NTU 95% time</li> <li>Maximum turbidity:≤ 0.30 NTU</li> <li>Continuous monitoring for IFE and CFE (capture highest value per day from SCADA)</li> </ul>							

Attached are plant summary reports from Optimization Assessment for a surface water treatment plant. Within your small group, review and evaluate the performance data. Be prepared to discuss your answers to the questions.

#### <u>Plant 1:</u>

#### 1) What are the turbidity goals for this plant? How is it performing relative to each specific goal?

The average of the maximum daily raw water turbidities over the year was 3.5 NTU, which is below 10 NTU so the goal would be 1.0 NTU for maximum daily settled water turbidity.

The plant met the 1.0 settled water turbidity goal only on about 56% of the days and the 95<sup>th</sup> percentile of the maximum daily settled water turbidity was 3.6 NTU, slightly above the 1.0 NTU optimization goal. There is some room for performance improvement related to the settled water turbidity goal.

The plant met the individual filter turbidity goal on about 59% of the days and the 95<sup>th</sup> percentile of the individual filter maximum daily turbidity was 0.63 NTU, quite a bit higher than the optimization goal of 0.10 NTU.

The plant met the combined filtered water turbidity goal on about 94% of the days and the 95<sup>th</sup> percentile of the combined filtered maximum daily turbidity was 0.21 NTU, above the goal of 0.10 NTU. There is some room for improvement in the combined filtered water turbidity removal plant performance.

#### 2) Identified areas for performance improvement (i.e., if this were your plant, where would you focus your optimization efforts?).

In the months near the end of the performance period, increasing raw water turbidity seemed to pass through the plant, demonstrated by higher settled water maximum daily turbidity values and higher individual filter maximum daily turbidity values. The operators could try to improve their clarification process, and in turn may reduce filter loading and may also improve filter performance. Filter 4 had a 95<sup>th</sup> percentile maximum daily turbidity of 0.77 NTU for the year,
significantly higher than the other filters. The annual 95<sup>th</sup> percentile for filters 1, 2 and 3 were also significantly higher than filters 5 through 8. It would be worth investigating why one half of the filters in the plant seem to perform better than the other half.

#### 3) Are there any possible data integrity issues that might be evident from the data summaries?

The maximum of the maximum daily combined filter turbidity readings is 0.30 NTU. This could be due to a control system automatic shut off if the turbidity reaches that value, but it could also be a data capping situation. It should be investigated.

The maximum daily settled water turbidity data are all from one sample location (Sed 1). If there are multiple trains in the plant, the data are most likely collected on top of the filters, representing combined flow from the multiple trains. The situation should be investigated, and the operators should adopt a policy of collecting data at least every 4 hours from each individual train to be able to assess the performance of each basin separately.



Plant 1 Turbidity Profile Trend

ANNUAL DATA	Avg	Min	Max	95%	Opt. Goal
	NTU	NTU	NTU	NTU	% Values
Raw Turbidity	3.5	1.0	10.8	7.5	n/a
Max. Settled Turbidity	1.4	0.3	6.0	3.6	56
Max. Filtered Turbidity	0.24	0.06	0.86	0.63	59
Combined Filtered Turbidity	0.13	0.07	0.30	0.21	94

Plant 1 Summary

		Settled	Water Tu	irbidity		Filtered Water Turbidity										
	95th P	ercentile	Values	(NTU)		95th Percentile Values (NTU)										
	Sed 1	Sed 2	Sed 3	Sed 4	All Sed	Filter 1	Filter 2	Filter 3	Filter 4	Filter 5	Filter 6	Filter 7	Filter 8	Combined		
Jan-18	1.81				1.81	0.26	0.29	0.26	0.26	0.17	0.18	0.12	0.14	0.25		
Feb-18	1.13				1.13	0.22	0.17	0.22		0.14		0.10		0.18		
Mar-18	1.17				1.17	0.13	0.17		0.15	0.12				0.14		
Apr-18	1.33				1.33		0.20	0.14		0.13	0.10			0.12		
May-18	0.96				0.96	0.24	0.28	0.27	0.24	0.21	0.22	0.19		0.23		
Jun-18	1.07				1.07	0.30	0.19	0.27	0.29	0.19	0.19			0.20		
Jul-18	2.57				2.57	0.25	0.28	0.23	0.23	0.20	0.20	0.23		0.19		
Aug-18	2.52				2.52	0.50	0.18	0.39	0.48	0.20	0.22	0.20		0.17		
Sep-18	5.20				5.20	0.53	0.77	0.63	0.84		0.27	0.32	0.20	0.24		
Oct-18	3.42				3.42	0.48	0.38	0.44	0.49	0.09	0.20	0.20		0.17		
Nov-18	3.70				3.70	0.35	0.33	0.21	0.25		0.18	0.20		0.16		
Dec-18																
Yr. 95%	3.61					0.43	0.59	0.50	0.77	0.19	0.23	0.27	0.19	0.21		
Yr. Goal	55.6%					67.3%	68.9%	<mark>61.1%</mark>	54.7%	97.4%	87.4%	82.3%	100.0%	94.4%		

Plant 1 Monthly Performance by Basin and Filter



Plant 1 Max Daily Settled Water Turbidity Trend and Individual Filter Max Daily Turbidity Trend

## Surface Water Treatment Optimization Training West Fargo, North Dakota April 22, 2025

#### AWOP Workshop: Performance Data Interpretation and Assessment

Prepared by:

Process Applications, Inc. 2627 Redwing Road, Suite 340 Fort Collins, CO 80526

and

U.S. Environmental Protection Agency Office of Ground Water and Drinking Water Technical Support Branch 26 W. Martin Luther King Drive Cincinnati, Ohio 45268

#### AWOP Workshop: Performance Data Interpretation and Assessment

## **Instructions**:

Collecting and assessing plant performance data is an important step to establish the status of a plant relative to achieving optimized performance goals. The purpose of this workshop is for the participants to explore methods for summarizing and evaluating a plant's historical performance data and to develop interpretation skills.

Below are the optimization performance goals for the sedimentation barrier and the filtration barrier.

		Performance Goals
Sedimentation       • Max Daily Turbidity:         • 2 NTU 95% time when source turbidity >10 NTU         • Max Daily Turbidity:         • 1 NTU 95% time when source turbidity ≤ 10 NTU         • Frequency of sampling:         • Grab – every 4 hours         • Continuous – capture highest value per day from SCADA	•	y Turbidity: NTU 95% time when source turbidity >10 NTU y Turbidity: NTU 95% time when source turbidity ≤ 10 NTU y of sampling: rab – every 4 hours ontinuous – capture highest value per day om SCADA

Filtration	• Max Daily Turbidity: $\leq 0.10$ NTU 95% time
	● Maximum turbidity:≤ 0.30 NTU
	• Continuous monitoring for IFE and CFE (capture highest value per day from SCADA)

Attached are plant summary reports from Optimization Assessment for a surface water treatment plant. Within your small group, review and evaluate the performance data. Be prepared to discuss your answers to the questions.

#### Plant 2:

1) What are the turbidity goals for this plant? How is it performing relative to each specific goal? *The average of the maximum daily raw water turbidities over the year was 2.8 NTU, which is below 10 NTU so the goal would be 1.0 NTU for maximum daily settled water turbidity.* 

The plant met the 1.0 settled water turbidity goal only on about 18.6% of the days and the 95<sup>th</sup> percentile of the maximum daily settled water turbidity was 2.4 NTU, slightly below the average daily maximum raw water turbidity and above the optimization goal. There is room for performance improvement related to the settled water turbidity goal.

The plant met the individual filter turbidity goal on about 100% of the days and the 95<sup>th</sup> percentile of the individual filter maximum daily turbidity was 0.04 NTU, indicating optimized performance of the filtration barrier.

The plant met the combined filtered water turbidity goal 100% of the days also, and the 95<sup>th</sup> percentile of the combined filtered maximum daily turbidity was 0.06 NTU, within the goal of 0.10 NTU. Together with the individual filter performance data, the combined filtered water performance indicates the plant filtration barrier is optimized.

2) Identified areas for performance improvement (i.e., if this were your plant, where would you focus your optimization efforts?).

The operators of Plant 2 would look to optimize their sedimentation performance. In reviewing the performance of each basin individually, the performance seems to be better from Sed 2 (1.75 NTU max daily turbidity 95th percentile) vs. basin 1 (2.42 NTU max daily turbidity 95th percentile). Operators should investigate the operational differences between the basins.

#### 3) Are there any possible data integrity issues that might be evident from the data summaries?

There is only one month of data from Sed 3 and incomplete annual data from Sed 2. Are Sed two and Sed 3 available and not operated part of the year or is the data set incomplete? Either way the

operators should find a way to operate all basins or collect at least 4-hour settled water turbidity samples from all active trains.



Plant 2 Turbidity Profile Trend

ANNUAL DATA	Avg	Min	Max	95%	Opt. Goal	
	NTU	NTU	NTU	NTU	% Values	
Raw Turbidity	2.8	0.3	8.9	5.2	n/a	
Max. Settled Turbidity	1.5	0.5	4.8	2.4	18.6	
Max. Filtered Turbidity	0.03	0.02	0.06	0.04	100.0	
Combined Filtered Turbidity	0.05	0.04	0.08	0.06	100.0	

## **Plant 2 Summary**

	Settled Water Turbidity													Filtere	d Water	Turbidi	ty					
	951	h Perce	ntile Va	lues (N1	ΓU)	% Va Meetin	lues g Goal	95th Percentile Values (NTU)														
	Sed 1	Sed 2	Sed 3	Sed 4	All Sed	2 NTU	1 NTU	Filter 1	Filter 2	Filter 3	Filter 4	Filter 5	Filter 6	Filter 7	Filter 8	Filter 9	Filter 10	Filter 11	Filter 12	Filter 13	Filter 14	Combined
Jun-18	2.47	2.00			2.45	82.76	17.2	0.03	0.03	0.03	0.03	0.04	0.03	0.04	0.03	0.05	0.03	0.03	0.03	0.03	0.03	0.06
Jul-18	2.52	1.88			2.39	90.00	15.0	0.03	0.03	0.03	0.03	0.03	0.04	0.03	0.03	0.05	0.03	0.03	0.03	0.03	0.03	0.07
Aug-18	2.24	1.56	1.89		1.93	95.77	21.1	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.06
Sep-18	2.35	1.70			2.27	86.96	26.1	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.05	0.03	0.03	0.03	0.03	0.03	0.03	0.05
Oct-18	2.40				2.40	77.42		0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.04	0.03	0.03	0.03	0.03	0.03	0.05
Nov-18	2.16				2.16	86 67	67	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.06
Dec-18	2.03				2.03	93 55		0.02	0.02	0.02	0.02	0.02	0.02	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.06
Jan-19	2.06				2.06	93.55	97	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.05
Feb-19	1 87				1.87	96.43	17.9	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.05
Mar-19	1 99	0 99			1.98	96.88	81.3	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.05
Apr 10	1.00	1 49			1 49	06.67	72.2	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.05
Api-19	2.44	0.92			2.27	90.07	27.1	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.05
Way-19	2.41	0.02			2.31	00.07	31.1	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.05
Yr. 95%	2.42	1.75	1.89					0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.04	0.03	0.03	0.03	0.03	0.03	0.03
Yr. Goal	6.5%	54.4%	66.7%					100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Plant 2 Monthly Performance by Basin and Filter



Plant 2 Max Daily Individual Sedimentation Basin Settled Water Turbidity Trend



Plant 2 Max Daily Individual Filter Turbidity Trend



Plant 2 Max Daily Individual Filter Turbidity Trend continued



Plant 2 Max Daily Individual Filter Turbidity Trend continued

## Surface Water Treatment Optimization Training West Fargo, North Dakota April 22, 2025

#### AWOP Workshop: Performance Data Interpretation and Assessment

Prepared by:

Process Applications, Inc. 2627 Redwing Road, Suite 340 Fort Collins, CO 80526

and

U.S. Environmental Protection Agency Office of Ground Water and Drinking Water Technical Support Branch 26 W. Martin Luther King Drive Cincinnati, Ohio 45268

#### AWOP Workshop: Performance Data Interpretation and Assessment

## **Instructions**:

Collecting and assessing plant performance data is an important step to establish the status of a plant relative to achieving optimized performance goals. The purpose of this workshop is for the participants to explore methods for summarizing and evaluating a plant's historical performance data and to develop interpretation skills.

Below are the optimization performance goals for the sedimentation barrier and the filtration barrier.

Barrier	Performance Goals
Sedimentation	<ul> <li>Max Daily Turbidity:         <ul> <li>2 NTU 95% time when source turbidity &gt;10 NTU</li> </ul> </li> <li>Max Daily Turbidity:         <ul> <li>1 NTU 95% time when source turbidity ≤ 10 NTU</li> </ul> </li> <li>Frequency of sampling:             <ul> <li>Grab – every 4 hours</li> <li>Continuous – capture highest value per day</li> </ul> </li> </ul>
	from SCADA

Filtration	• Max Daily Turbidity: $\leq 0.10$ NTU 95% time
	● Maximum turbidity:≤ 0.30 NTU
	• Continuous monitoring for IFE and CFE (capture highest value per day from SCADA)

Attached are plant summary reports from Optimization Assessment for a surface water treatment plant. Within your small group, review and evaluate the performance data. Be prepared to discuss your answers to the questions.

#### Plant 3:

1) What are the turbidity goals for this plant? How is it performing relative to each specific goal? *The average of the maximum daily raw water turbidities over the year was 10.4 NTU, which is above 10 NTU so the goal would be 2.0 NTU for maximum daily settled water turbidity.* 

The plant never met the 2.0 settled water turbidity goal and the 95<sup>th</sup> percentile of the maximum daily settled water turbidity was 15.2 NTU, well above the goal. Settled water performance could definitely be improved.

The plant met the individual filter turbidity goal only on 6% of the days and the 95<sup>th</sup> percentile of the individual filter maximum daily turbidity was 2.00 NTU, indicating poor performance from the filtration barrier.

The plant met the combined filtered water turbidity goal 37% of the days and the 95<sup>th</sup> percentile of the combined filtered maximum daily turbidity was 0.32 NTU, well above the combined filtered water goal of 0.10 NTU.

# 2) Identified areas for performance improvement (i.e., if this were your plant, where would you focus your optimization efforts?)

Both the sedimentation and filtration barriers are in need of improved performance improvement. In reviewing the individual sedimentation data, it appears that two trains are available but only one is used at a time. When operating, Sed 2 seems to perform better than Sed 1. (The 95th percentile of the Sed 2 max daily turbidities is 10.94 for the year vs. 16.87 for Sed 1). Operators should focus on overall improvement to the sedimentation process, which may improve filer performance as well if coagulant feeds can be optimized.

The individual filter data is capped at 2.0 NTU and the 95th percentile is at that limit for 7 of the 14 filters. Filter 10 seems to perform much better than the other filters, even though it's max daily turbidity 95th percentile (0.28 NTU) is still above the optimization goal. Operators should

investigate the large difference between the filtered water turbidity readings at Filter 10 to determine if filter operation or data integrity is causing the difference.

#### 3) Are there any possible data integrity issues that might be evident from the data summaries?

There are signal span/data capping issues. The individual filter turbidity data seems to be capped at 2.0 NTU and the combined filtered turbidity data seems to be capped at 1.0 NTU.

There is a large discrepancy between the filter performance at filter 10 compared to the other filters, which could be due to a data integrity issue.

There is much variation in the maximum daily individual filter turbidity trend line, possibly caused by some sort of data integrity issue.

Although the summary table shows ave., max., and min values for the daily raw water turbidity, there is insufficient data to graph on the plant profile and likely insufficient data to confidently set the settled water goal and to read trends that the profile graph might display. Operators should collect at least daily raw water turbidity samples and run analyses.



**Plant 3 Turbidity Profile Trend** 

ANNUAL DATA	Avg	Min	Max	95%	Opt. Goal	
	NTU	NTU	NTU	NTU	% Values	
Raw Turbidity	10.4	8.6	12.2	12.0	n/a	
Max. Settled Turbidity	8.5	0.1	23.8	15.2	0	
Max. Filtered Turbidity	1.33	0.03	2.00	2.00	6	
Combined Filtered Turbidity	0.14	0.05	1.00	0.32	37	

**Plant 3 Summary** 

	Settled Water Turbidity						Filtered Water Turbidity											
	95th Pei Values	rcentile (NTU)		Percent Go	Meeting pal	95th Percentile Values (NTU)												
	Sed 1	Sed 2	All Sed	2 NTU	1 NTU	Filter 1	Filter 2	Filter 3	Filter 4	Filter 5	Filter 6	Filter 7	Filter 8	Filter 9	Filter 10	Filter 11	Filter 12	Combined
Jun-18		11.40	11.40			2.00	2.00	1.84	0.39	0.42	0.50	0.36	1.94	0.54	0.08	2.00	1.24	0.15
Jul-18		11.05	11.05															0.14
Aug-18		11.06	11.06															0.16
Sep-18		8.30	8.30	3.33	3.3	1.09	0.05	0.13	0.08	0.13	0.04	0.05	0.31	0.10	0.03	0.08	0.33	0.14
Oct-18		12.40	12.40			2.00	0.38	0.72	0.19	0.25	0.15	2.00	0.22	0.37	0.11	0.60	0.27	0.13
Nov-18	13.46	8.29	12.77			2.00	0.58	0.75	0.11	0.27	0.45	1.43	1.30	0.51	0.08	0.88	1.44	0.16
Dec-18	10.25		10.25			1.95	0.54	0.39	0.03	0.54	0.26	0.25	2.00	0.90	0.14	1.49	0.97	0.13
Jan-19	8.97		8.97			0.88	1.32	0.48	1.24	0.43	2.00	0.49	2.00	2.00	0.27	0.76	0.76	0.14
Feb-19	11.12		11.12			0.85	2.00	0.38	1.71	1.42	1.85	0.80	1.71	0.81	0.29	0.92	1.27	0.15
Mar-19	15.55		15.55			2.00	2.00	0.98	2.00	1.58	1.18	2.00	2.00	2.00	0.28	1.91	2.00	0.20
Apr-19	21.93		21.93			2.00	2.00	2.00	1.30	0.43	1.82	0.56	1.04	1.72	0.26	2.00	2.00	0.82
May-19	20.28	10.05	17.80			2.00	2.00	2.00	1.63	0.38	1.19	0.22	1.08	2.00	1.80	2.00	2.00	0.52
Yr. 95%	16.67	10.94			1	2.00	2.00	2.00	1.63	0.57	1.48	1.11	2.00	2.00	0.28	2.00	2.00	0.32
Yr. Goal		0.6%				24.2%	32.0%	29.7%	49.4%	51.3%	63.2%	50.2%	56.5%	31.6%	79.2%	30.9%	47.0%	37.4%

## Plant 3 Monthly Performance by Basin and Filter



Plant 3 Max Daily Individual Sedimentation Basin Settled Water Turbidity Trend

- 8 -



Plant 3 Max Daily Individual Filter Turbidity Trend



Plant 2 Max Daily Individual Filter Turbidity Trend continued