

<image><image><image><image><image><image>







Bismarck Water Treatment

Source Waters

- Missouri River surface water
 - Used in peak months (May/June-October)
- Horizontal Collector Well
 - Bank filtration on the east bank of Missouri River
 - Used in low flow months through spring runoff period (November-May)
 - Groundwater Influenced Quality
 - Iron and Manganese present



Bismarck Water Treatment

Existing Process

- 1. Screening
- 2. Lime Softening
- 3. Filtration
- 4. Disinfection
- 5. Residuals Handling
- Capacity (MGD)
- 1. Current 30

	Actuals	Projec	ctions
Year	2020	2030	2040
Average Demand - MGD	10.1	12.3	14.2
Peak Demand - MGD	27.5	32.5	40.2



Bismarck Water Treatment Planned 10 MGD Expansion 1. Source Water Blending Missouri River Intake Collector Well

2. Pretreatment

- Oxidation
- Sedimentation/Sand Removal
- 3. Microfiltration-Ultrafiltration (MF/UF)
- 4. Reverse Osmosis (RO)
- 5. Disinfection

9

6. Residuals Handling Improvements







12

Ceramic vs Polymeric

- City of Bismarck interest in possible advantages of ceramics compared to PVDF lead to decision to development a pilot program with multiple MF-UF Modules
- Number Possible Ceramic Advantages
 - Longer membrane life
 - Typical higher flux rates
 - · Potential for fewer fouling issues
 - Ability to handle higher strength of cleaning chemicals
 - High thermal stability



MF/UF Pilot Program Objectives and Goals

- Obtain sufficient data required for ND DEQ review process for ceramic membrane systems for both City of Bismarck raw source waters (surface water and collector well), minimum of 2 cleaning cycles total.
- Determine optimum flux, coagulant feed rates, backwash and cleaning frequency on each raw water source to provide basis of design for full-scale membrane system procurement
- Optimize cleaning chemical cleaning strategy - run continuously for 30 days on each Bismarck source water without requiring a CIP.
- 4. Meet turbidity reduction and recovery goals for each raw water source



14

Piloted Systems

- Submerged PVDF (Top Left)
 - Surface Water Only
- Pressurized PVDF (Module A Right)
- Pressurized Ceramic I (Module B Right)
- Pressurized Ceramic II (Middle Left)
- Submerged Ceramic (Bottom Left)





Submerged PVDF

- PVDF Polyvinylidene Fluoride
- Cassettes that can be stacked and submerged in a basin
- Cassette Dimensions:
 - 27" height, 27.2" width, 4.2" length
 - 3,084.5 cubic inch volume
- 0.02 micron nominal pore size (UF)
- Fiber OD 0.95mm
- Membrane Module Surface Area 550 sf
- Flow path Outside In

Pressurized PVDF

- PVDF Polyvinylidene Fluoride
- Cylindrical pressurized module
- Dimensions
 - 8.5" diameter, 85" length
 - 4,820.9 cubic inch volume
- 0.01 micron nominal pore size (UF)
- Membrane Module Surface Area 969 sf



Pressurized Ceramic I

- Silicon Carbide (SiC) Segmented Module
- Cylindrical pressurized module
- 10" diameter, 75" length
 - 5,887.5 cubic inch volume
- 0.04 micron nominal pore size (UF)
- Membrane Surface Area 244 sf
- Hydrophilic (Attracted to Water)



18

Pressurized Ceramic II

- Alumina Monolithic Module
- · Cylindrical pressurized module
- Inside-out filtration
- Module Dimensions
 - 7.1" diameter, 59.1" length
 - 2,338.7 cubic inch volume
- 0.1 micron nominal pore size (MF)
- Membrane Module Surface Area 269 sf
- Hydrophilic (Attracted to Water)



Submerged Ceramic

- Alumina Ceramic
- Plates that are stacked on top of each other
- Outside-in filtration
- Plate Stack
 - 28" length, 22.7" width, 6.3" height
 - 4,004.3 cubic inch volume
- 0.05 micron nominal pore size (UF)
- Membrane Stack Surface Area 64.6 sf
- Hydrophilic (Attracted to Water)



20



03 UF Piloting - Surface Water

Membrane Acronym Refresher

- Flow GPM Gallon Per Minute
- Flux GFD Gallons per Sq. Foot per Day
 - Normalized Flux Temperature Correct Flux @ 20 deg C
- Transmembrane Pressure TMP
- CIP Clean In Place
- Production Cycle Length of Time Between Backwashes
- Recovery % of Total Permeate Volume / Total Feed Volume
- Permeability Flux/TMP
- HCW Horizontal Collector Well

22

Submerged PVDF				
Operating Cond	itions	Table	sure (PSI)	
Description	Units	Submerged PVDF	Pres	
Flowrate	GPM	17.2	4 -	
Instantaneous Flux (Normalized)	GFD	45-50 (50-65)		
Coagulant Dose	Mg/L	1.7	Trans	
Production Cycle Time	Min	23-33	7/27/20	
Recovery	%	95-96		
CIP			Flux Set Poin Coagulant D	
12.5% Sodium Hypochlorite Dose	Mg/L	500		
50% Citric Acid Dose	Mg/L	2,000	• TMP	
Hypo CIP Permeability Recovery	%	78	wate	
Acid CIP Permeability Recovery	%	22	psi/d	
Total CIP Permeability Recovery	%	95.6	15.4	
Coagulant used was Aquahawk 607 (Aluminum chlorohydrate)				



ACRONYM'S

EVERYWHERE

- TMP ranged from 5-8 psi throughout the surface water trial.
- The observed linear fouling rate was 0.10 psi/day at the average water temperature of 15.4C.
- 2 Maintenance Cleans per week.

Pressurized PVDF

Operating Conditions Table

Description	Units	Pressurized PVDF	
Flowrate	GPM	30	
Instantaneous Flux (Normalized)	GFD	44.5-46.5 (50-70)	
Coagulant Dose	Mg/L	0	
Production Cycle Time	Min	30-45	
Recovery	%	>96	
CIP			
12.5% Sodium Hypochlorite Dose	Mg/L	3,000	
50% Citric Acid Dose	Mg/L	5,000	
Total CIP Permeability Recovery	%	98.1	
		9	

Coagulant used was Aquahawk 607 (Aluminum chlorohydrate)



- TMP ranged from 9-13 psi throughout the surface water trial.
- The observed fouling was 4 psi between CIPs at a normalized water temperature of 20C.
- Maintenance Clean Frequency 50 backwashes



Pressurized Ceramic II

Operating Conditions Table

Description	Units	Pressurized Alumina	
Flowrate	GPM	18.7-33	
Instantaneous Flux (Normalized)	GFD	100-175 (100-250)	
Coagulant Dose	Mg/L	(10-14)	
Production Cycle Time	Min	60	
Recovery	%	98.5	
CIP			
12.5% Sodium Hypochlorite Dose	Mg/L	3,000	
50% Citric Acid Dose	Mg/L	10,000	
Total CIP Permeability Recovery	%	98.7	

Coagulant used was Aquahawk 607 (Aluminum chlorohydrate)



- dose(mechanical issue) seen on 9/2 and 10/29. Neglecting these spikes, TMP ranged from 2-12 psi between CIPs at a normalized water temperature of 20C.
- Maintenance Cleans performed daily.

Submerged Ceramic Operating Conditions Table			
Description	Units	Submerged Alumina	
Flowrate	GPM	13.7	
Instantaneous Flux (Normalized)	GFD	100 (122-146)	
Coagulant Dose	Mg/L	(4-15)	
Production Cycle Time	Min	60	
Recovery	%	95.6	
CIP			
12.5% Sodium Hypochlorite Dose	Mg/L	2,655	
50% Citric Acid Dose	Mg/L	10,185	
Hypo CIP Permeability Recovery	%	89	
Acid CIP Permeability Recovery	%	11	
Total CIP Permeability Recovery	%	96.7	
Coagulant used was Aquahawk 607 (Aluminum chlorohydrate)			



- TMP ranged from 2-10 psi between CIPs. Operating temperatures ranged from 40-60F throughout the surface water trial.
- Maintenance Cleans were performed once daily.



UF Piloting - HCW Water



Pressurized Ceramic I

Operating Conditions Table

Description	Units	Pressurized Silicon Carbide	
Flowrate	GPM	33 9-37 3	
Instantaneous Flux (Normalized)	GFD (175-220 (150-275)	
Coagulant Dose	Mg/L	1 <u>9 - 0</u>	
Production Cycle Time	Min	20	
Recovery	%	>96	
CIP			
12.5% Sodium Hypochlorite Dose	Mg/L	3,000	
50% Citric Acid Dose	Mg/L	5,000	
Total CIP Permeability Recovery	%	>95	



- TMP stayed around 8 psi throughout the HCW water trial.
- The observed fouling was negligible at normalized water temperature of 20C.
 - Maintenance Clean ranged between 34-108 backwashes. Optimized at 108 backwash interval



Submerged Ceramic

Operating Conditions Table

Description	Units	Submerged Alumina	
Flowrate	GPM	13.7	
Instantaneous Flux (Normalized)	GFD 🤇	100-101.5 (122-146)	
Coagulant Dose	Mg/L	1 <u>5 - 0</u>	
Production Cycle Time	Min	53-60	
Recovery	%	95.1	
CIP			
12.5% Sodium Hypochlorite Dose	Mg/L	2,243	
50% Citric Acid Dose	Mg/L	10,401	
Hypo CIP Permeability Recovery	%	0	
Acid CIP Permeability Recovery	%	100	
Total CIP Permeability Recovery	%	1041	
¹ - Values greater than 100% can be caused by variances in flux, water temperature, and other			

¹ - Values greater than 100% can be caused by variances in flux, water temperature, and other factors during clean membrane permeability calculation and post CIP permeability calculation.



- TMP ranged from 2-3 psi throughout the HCW water trial. Observed fouling was minimal.
- TMP ranged from 0.5-2 psi at a normalized water temperature of 20C.
- Maintenance Cleans were performed once daily.

32



05 UF Piloting Conclusions



Submerged PVDF

- Take Aways
 - Performed as expected with surface water piloting – Recovery, chemical usage, cleaning rates, low coagulant usage
 - Known Missouri River water performance and pilot results indicated no significant deviation at the Bismarck location
 - Small basin area requirements; potentially allowing for future expansion within existing footprint
 - Lower flux rates (40-45 GFD) and recovery (95-96%)
 - Hands-on operating experience for Operations staff

Pressurized Polymeric

- Take Aways
 - Performed as expected with surface water and HCW sources
 - Slightly higher recovery than submerged PVDF
 - Lowest coagulant usage among piloted modules
 - More maintenance typically compared to ceramic pressurized module, but no pinning required during piloting
 - Lower flux rates (46 GFD), slightly higher than submerged PVDF



Pressurized Ceramic I

- · Trends and Takeaways
 - Performed well on HCW
 - Reached 200 GFD with stable operation
 - Pilot did not demonstrate stable treatment of Missouri River surface water
 - Did not meet ND DEQ requirement of 30 days run time without conducting CIP on surface water



36

Pressurized Ceramic II

- Trends and Takeaways
 - Performed extremely well on both Surface and HCW source waters; long run times, relatively low chemical usage, extremely high recovery (~98-99%)
 - Highest stable flux rates (200 GFD) of the membranes piloted
 - Higher coagulant dosage required for surface water compared to PVDF
 - Long warranty, and lower O&M costs likely compared to pressurized PVDF



<section-header> Submerged Ceramic Trends and Takeaways Performed well on both Surface and HCW; long run times, relatively low CEB-CIP chemical usage Long warranty, and lower O&M costs likely compared to PVDF submerged Higher flux rates than comparable PVDF but significantly lower than the alumina pressurized module Limited US installations Large basin requirement, little to no room for expansion Higher coagulant dosage required for surface water compared to PVDF







07 City of Bismarck CMAR Program Overview

42

WTP and WWTP Improvements CMAR Program

- Multiple facilities, locations, schedules, subcontractors, funding sources
- 9 total GMPs
- Projects ranging from new structures, forcemain, control structures, HVAC systems, SCADA network backbone, UF piloting, regional CO2 storage



Thank You

H



Dakotas/Wyoming Drinking Water Market Sector Lead

Email: jarrett.Hillius@hdrinc.com

Phone: 701-557-9637



Dakotas/Wyoming Drinking Water Treatment Business Lead

Email: joseph.honner@hdrinc.com

Phone: 605-782-8138